



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on April 18, 2019.

EnviroTech Chemical Services, Inc.
500 Winmoore Way
Modesto, CA 95358
888-563-2254
209-581-9576

Facility: Modesto, CA

Chemical/ Trade Designation	Function	Max Use
Ammonium Sulfate		
BSLLAS	Chloramination	60 mg/L
Hydrogen Peroxide		
Hydrogen Peroxide 15%	Oxidant	3.5 mg/L
Hydrogen Peroxide 34%	Oxidant	3 mg/L
Hydrogen Peroxide 50%	Oxidant	2.1 mg/L
Miscellaneous Treatment Chemical		
Bioside HS 15% ^[2]	Membrane Cleaner Reverse Osmosis Antiscalant	30 mg/L
Miscellaneous Water Supply Products		
ECO9000 ^[1]	Other	NA
Perasan A ^{[3] [4] [5]}	Membrane Cleaner	NA
REFLEX [™] ^{[3] [4] [5]}	Membrane Cleaner	NA

[1] ECO 9000 is used offline to remove deposits from water tank surfaces. It is used in a 10:1 ratio at a rate of 60 mg/L with Hydrogen Peroxide 34%. The tank is rinsed to remove any residual product before returning to service.

[2] This product is designed to be used upstream of a carbon absorption system. Use of this product shall be followed by chlorination to remove trace levels of hydrogen peroxide.

[3] These products are designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.

[4] The pH of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.

[5] Drain and flush system until the hydrogen peroxide and peracetic acid concentrations fall below 1 ppm.

Facility: Helena, AR

Chemical/ Trade Designation	Function	Max Use
Hydrogen Peroxide^[HP]		
Hydrogen Peroxide 27%	Oxidant	3 mg/L
Hydrogen Peroxide 34%	Oxidant	3 mg/L
Miscellaneous Water Supply Products^{[1] [2] [3]}		
Bioside HS 15%	Membrane Cleaner	NA

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.



Perasan A	Membrane Cleaner	NA
REFLEX™	Membrane Cleaner	NA

- [1] This product is designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.
- [2] The pH of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.
- [3] Drain and flush system until hydrogen peroxide and peracetic acid concentrations fall below 1 ppm.
- [HP] Use of this product shall be followed by chlorination to remove levels of hydrogen peroxide. Chlorine residuals shall not exceed 4 mg/L, the EPA's proposed maximum residual level.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

2 of 2